

PAN : AACA2551J

CIN : U771200DL2023PTC418835



ACE TEST HOUSE (P) LTD.

(GOVT. APPROVED TESTING LABORATORY)
ISO 9001-2015 OHSAS 45001:2018 ISO 14001:2015
Certified Testing Laboratory



Committed to Precision....

TAX INVOICE

PAN No.: AACZCA2551J	GSTIN No.: 07AAZCA2551J1Z8	INVOICE NO	587
SR :	Direct	DATED	30-03-2026
Bill to RAJAT CONSTRUCTION CO C-140, SFS FLATS, DIVYA JYOTI APARTMENT, SECTOR-19, ROHINI, New Delhi, North Delhi, Delhi, 110089		Place of Supply The Talagang Co-Op. Group Housing Society Ltd. NEELKANTH APARTMENTS Plot NO 49, Sector-13 Rohini, Delhi-110085	
GSTIN : 07ABJFR0551M1ZX			

Sub : Testing charges for the following work

Name of Work : Construction of roads with interlocking Paver blocks and construction of rainwater drainage system including connection of PVC Pipes with existing rainwater Pipes of all blocks of The Talagang Co-op Group Housing Society Ltd, Neelkanth Apartments Sector-13, Rohini, Delhi M/s Rajat Construction Co.

Name of Agency : M/s Rajat Construction Co.
Ref : TCGHS/2025-26/224 Lt.Dt. 27.03.2026
Agmt No. : -

S.No	Description of Sample	SAC/HSN	Quantity	Rate	Amount
1.	Paver Block 80mm (Comp.) Job ID No 20-20260327-01	998346	1.00	1,500.00	1,500.00
Total					₹ 1,500.00
<i>Less : Discount</i>					<i>@ 35.00 %</i>
<i>Add : CGST</i>					<i>@ 9.00 %</i>
<i>Add : SGST</i>					<i>@ 9.00 %</i>
<i>Add : Rounded Off (+)</i>					<i>0.50</i>
Note:- Please deduct the TDS @ 2% us/194C as per Income Tax Act, 1961. (if required)				Grand Total	1.00 ₹ 1,151.00

Rupees One Thousand One Hundred Fifty One Only

Instruction : Cheques/ Drafts should be made in faovur of ACE TEST HOUSE PVT LTD, DELHI

Our bank details for RTGS/NEFT Transfer:

Bank Name : YES BANK
A/C No. : 060863300003022
Branch : VIVEK VIHAR, Delhi
IFSC CODE : YESB0000608

For ACE TEST HOUSE PVT LTD

Authorised Signatory

Page No. 1

Delhi ♦ Dehradun Reg. No. DL-06-0118893 Jaipur ♦ Jammu

Head Office. Kh. No. 1048/1088, Pepsi Wali Gali, Near Laxmi Narayan Mandir, Village-bhalaswa, Delhi-110033
.M: +91-7042858881/82/83 E-mail : acetesthouse@gmail.com, website : www.acetesthouse.com



ACE TEST HOUSE (P) LTD.

Committed to Precision....

KH. No. 1048/1088, Pepsi Wali Gali, Near Laxmi Narayan Mandir, Village - Bhalaswa, Delhi-110033
M.: +91-7042858881/82/83 E-mail : acetesthouse@gmail.com, Website : www.acetesthouse.com

TEST REPORT



Job card No./Job ID. No.	20-20260327-01	Discipline.	Mechanical Testing	Page 1 of 1	
Report No.	ATH20-20260330-003	Group.	Building Material		
ULR No.	TC621426000000154F				
Sample Type	Paver Block-80mm	Make	K.K	Grade	M-35
Name and Address of Customer	The Talagang Co-Op Group Housing Society Ltd. "Neelkanth Apartments" Plot No. 49, Sector-13, Rohini, Delhi-110085				
Reference No.	TCGHS/2025-26/224				
Agreement No.	--			Dated	27/03/2026
Name of Work	Construction of roads with interlocking Paver blocks and construction of rainwater drainage system including connection of PVC Pipes with existing rainwater Pipes of all blocks of The Talagang Co-op Group Housing Society Ltd, Neelkanth Apartments Sector-13, Rohini, Delhi			Date of Receipt	27/03/2026
				Start Date of Analysis	28/03/2026
Name of Agency	M/s Rajat Construction Co.			End Date of Analysis	30/03/2026
Indian Standard Reference	IS: 15658-2021			Report Issue Date	30/03/2026
Test Performed at	Lab				
Any Other Information	Date of Collection:- 27.03.2026				

Sr. No.	Test Parameters	Units of Measurements	Results	Requirement as per IS: 15658-2021	Method Reference
1.	Compressive strength	N/mm ²	34.2	Average 39.125 Min. Individual 32.0 Min.	IS: 15658-2021 Annex-D
			32.5		
			32.5		
			34.6		
			33.9		
			33.7		
			34.3		
			36.1		
	Average	33.98			

Remarks: The sample does not conform to IS: 15658-2021 Grade (M-35) w. r. to the above tests. Decision rule as per ILAC G-8, Clause 4.2.1 (Binary rule for acceptance criteria).

End of Report

Reviewed By



Authorized Signatory
Mr. Bipin Bihari Nayak

Terms & Conditions : 1. Test reports are valid only for the sample tested in our laboratory. 2. Sample will be stored/kept in our stores for 30 days from the date of testing and shall be destroyed thereafter without any intimation. 3. Samples tested are Non-Returnable until specified at time of sample submission. 4. This report will not be valid for judicial purpose. 5. Total liability of our test house is limited to invoiced amount.